

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:53 am

PWS ID: UTAH07067 **Name:** SOUTH DUCHESNE CULINARY WATER
Legal Contact: SOUTH DUCHESNE WATER INCXX **Rating:** Approved
 JOE STEED **Rating Date:** 03/03/2004
Address: PO BOX 294 **Activity Status:** Active
 DUCHESNE, UT 84021
Phone Number: 435-738-6200
City Served (Area):
County: DUCHESNE COUNTY
System Type: Community **Last Inv Update:** 09/22/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 02/19/2009 **Total Dsgn Cap:**
Population: 128 **Surveyor:** PETER T KEERS **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	STEED, JOE		435-738-6200		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	128
			128 Total Svc Connections

Storage

Total Storage: 330,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST002	300 K TANK	Ground	300,000 GAL	Concrete		A	NO
ST001	30000 GALLON TANK	Ground	30,000 GAL	Steel		A	NO

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	PUMP STATION 1	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	UTAH07001 DUCHESNE	Active	CC				No	SW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.